

Propane Boiler Checklist

CUSTOMER INFORMATION

Account Number: _____ Phone Number: _____

Name/Business: _____

Service Address: _____

Appliance Manufacture & Date: _____

Model# _____ Serial# _____

INSPECTION CHECKLIST - (TECHNICIAN TO PUT INITIALS ON EACH COMPLETED ITEM)

- _____ 1. Inspect Circulating Pump(s)
- _____ 2. Clean Heat Exchanger
- _____ 3. Check Pressure Switch
- _____ 4. Inspect Pilot Tube (If Applicable)
- _____ 5. Check Pilot Assembly (If Applicable)
- _____ 6. Inspect Gas Valve
- _____ 7. Check Manifold Gas Pressure (Inches WC: _____)
- _____ 8. Check Inducer Motor Assembly (If Applicable)
- _____ 9. Check Water Pressure in System
- _____ 10. Remove Burner Tubes and Inspect
- _____ 11. Inspect Expansion Tank
- _____ 12. Perform Combustions Analysis (O2: _____ CO2: _____ CO: _____ Efficiency: _____)
- _____ 13. Test for Carbon Monoxide (CO: _____)
- _____ 14. Check for Leaks in Exhaust System
- _____ 15. Clean Flame Sensor
- _____ 16. Check Safety Damper and Operation
- _____ 17. Check Condensate Line/Condensate Pump
- _____ 18. Inspect Electrical Wiring to Pumps and Zone Control (If Applicable)
- _____ 19. Check Thermostat (Replace Batteries if Necessary)
- _____ 20. Inform Customer of Equipment Condition and Recommend Necessary Repairs:

INSPECTION COMPLETED BY

Inspection Date/Time: _____

Customer Signature: _____

Tech Name & Signature: _____